



THE ADMINISTRATION OF UNION TERRITORY OF LADAKH
OFFICE OF THE DIRECTOR FIRE AND EMERGENCY SERVICES UT LADAKH

(e-mail: iqp-ladakh@police.ladakh.gov.in)

(Office Phone No.01982-260888)

No: - PHQ/Dir/F&ES/UTL/2021- 3258-59

Dated:- 07/12/2021

Subject: Fire NOC in favour of Army Good will School Faroona, Kargil.

The report has been submitted by Superintendent of Police, Fire and Emergency Services, Ladakh regarding the inspection of the instant school which has been done by I/C Fire and Emergency Services, Kargil. The detailed report is as under:

Location/ Accessibility:

The School is constructed at Faroona, Kargil. It is located at Longitude 75.993370 and Latitude 34.3942230. The site is approximately 25 Kms away from Fire and Emergency Services Station, Kargil. It takes approximately 50 minutes to reach the site and is approachable for fire appliances.

Detail of building:

The School building has four blocks. The details of the block are as under:

1st block: It is single storied building. In the ground floor there are Principal office, staff room, and one laboratory. 06 class rooms and two windows in each class room. The size of the window is 6x4 feet. All the windows have provision to open. 1st floor have 06 class rooms.

2nd block: It is single storied building. In the ground floor, there are store room, staff room, 2 rooms for laboratory and five other rooms. Two windows in each room and the size is 6x4 feet. One window has provision to open.

3rd block: It is single storied building having 6 class rooms. Two windows in each class room. The size of the window is 6x4 feet. One side of window have provision to open.

4th block: It is single storied building having two class rooms. There are two windows in each class room. The size of the window is 6x4 feet. One side of the window have provision to open.

There are 259 students and 18 staffs.

The following Fire Safety equipment's found installed in School Building:

01. 06 number of ABC type fire extinguishers 4 kg capacity found installed in the School building.
02. 02 thousand litres underground water reserve tank placed in the School premises.
03. 04 number of sand bucket found installed in the premises of school building.

FIRE NOC is given in favor of Army Good will School Faroona, Kargil for a period of **One year** from the issuance of this letter provided the school management constructs 20 thousand litres of underground water tank in a time bound manner.

Director, F&ES, Ladakh
PHQ, Agaling, Leh

Copy to:

1. Principal, Army Good will School Faroona, Kargil for info
2. Superintendent of Police, F&ES, Ladakh for information and n/a

Principal
Army Goodwill School
Faroona, Kargil

Lt Col/Maj
OIC Account
624 SATA